

## Groundwater Conservation Districts in Groundwater Management Area 12

	<b>Brazos Valley</b>	<b>Fayette County</b>	<b>Lost Pines</b>	<b>Mid-East Texas</b>	<b>Post Oak Savannah</b>
<b>Exempt Wells</b>	50,000 (D/L) O/G - rig supply Not frac supply	25,000 (D/L) O/G - rig supply	25,000 (D/L) O/G - rig supply	50,000 (D/L) O/G - rig supply Not frac supply	25,000 (D/L) O/G - rig supply Not frac supply
<b>Frac Well Permits</b>	Yes	Yes	No	Yes	Yes
<b>Permit by Production Acreage</b>	X	X		X	X
<b>Production Acreage Assigned</b>	Varies based on aagpm (by aquifer)	2 ac-ft/ac/yr (cumulative)		3 ac-ft/ac/yr (cumulative)	2 ac-ft/ac/yr (cumulative)
<b>Permit by Beneficial Use</b>			X		
<b>DFC Enforcement Rule</b>	Yes	By Permit Amendment	By Permit Amendment	By Permit Amendment	Yes
<b>Managed by MAG or DFC</b>	DFC	DFC	DFC	DFC	DFC
<b>GM Permitted Wells</b>	≤ 150 ac-ft/yr	< 200 ac-ft/yr	< 200 ac-ft/yr (AG) < 50 ac-ft/yr (M&I)	≤ 10 ac-ft/yr* *soon to be ≤ 56 ac-ft	> 25,000 & uo 50,000 D/L Any Ag related (all sizes) Any frac well (all sizes)
<b>Permit Term Length</b>	1 – year 5 – year	5 – year	5 – year	5 – year or less	40 – year 1 – year (non-renewable)
<b>Renewals</b>	Length of permit term	Length of permit term	Length of permit term	Length of permit term	Review every 5 years
<b>Export Permit Required</b>	X	X	X	X	X
<b>Fee Structure</b>	Metered Production	Tax Based	Permitted Production	Metered Production	Permitted Production
<b>Meters Required Permitted Wells</b>	Yes	Yes	Yes	Yes	Yes
<b>Production Reported Permitted Wells</b>	Yes	Yes	Yes	Yes	Yes

	<b>Brazos Valley</b>	<b>Fayette County</b>	<b>Lost Pines</b>	<b>Mid-East Texas</b>	<b>Post Oak Savannah</b>
<b>Hydrogeologic Study Required</b>	400 – 800 ac-ft/yr (Evaluation) > 800 ac-ft/yr (Study)	≥ 200 ac-ft/yr		> 250 gpm	Required if permit goes to a hearing
<b>Monitoring Wells (frequency)</b>	Quarterly	Annually	Annually Continuously	Annually	Annually Continuously
<b>SPACING REQUIREMENTS</b>					
<b>Hooper</b>	2'/aagpm	0 – 1,000 gpm = 1'/gpm >1,000 gpm = 1,000' +0.5'/gpm		50 – 250 gpm = 1,000' 250 – 500 gpm = 1,500' >500 gpm = Case by case	2'/gpm
<b>Simsboro</b>	1'/aagpm	0 – 1,000 gpm = 1'/gpm >1,000 gpm = 1,000' +0.5'/gpm	≤ 500 gpm = 1,500' 501 – 1,000 gpm = 2,500' >1,000 gpm = 5,000'	50 – 250 gpm = 1,000' 250 – 500 gpm = 1,500' >500 gpm = Case by case	1'/gpm
<b>Calvert Bluff</b>	2'/aagpm	0 – 1,000 gpm = 1'/gpm >1,000 gpm = 1,000' +0.5'/gpm		50 – 250 gpm = 1,000' 250 – 500 gpm = 1,500' >500 gpm = Case by case	2'/gpm
<b>Carrizo</b>	2'/aagpm	0 – 1,000 gpm = 1'/gpm >1,000 gpm = 1,000' +0.5'/gpm	≤ 500 gpm = 1,500' 501 – 1,000 gpm = 2,500' >1,000 gpm = 5,000'	50 – 250 gpm = 1,000' 250 – 500 gpm = 1,500' >500 gpm = Case by case	“ “
<b>Queen City Sparta Yegua-Jackson</b>	2'/aagpm	0 – 1,000 gpm = 1'/gpm >1,000 gpm = 1,000' +0.5'/gpm		50 – 250 gpm = 1,000' 250 – 500 gpm = 1,500' >500 gpm = Case by case	≤50 gpm = 2'/gpm 50 – 100 gpm = 3'/gpm 100 – 150 gpm = 4'/gpm 150 – 200 gpm = 5'/gpm >200 gpm = 7'/gpm