

Cade Lakes Water Supply Corporation

Serving the Cade Lakes Community

26550 Ranch Road 12, Suite 1 * Dripping Springs, Texas 7820 * (512) 894-3322 * fax (512) 858-1414

September 10, 2021

Gary Westbrook, General Manager
Post Oak Savannah Groundwater Conservation District
310 East Avenue C
P.O. Box 92
Milano, Texas 76556

Re: Cade Lakes Water Supply Corporation ("CLWSC")
Post Oak Savannah Groundwater Conservation Grant 2021

Dear Mr. Westbrook:

First, on behalf of CLWSC, let me express our appreciation for the award of the District's 2021 Groundwater Conservation Grant. These funds will go a long way to assist with the conservation of our groundwater resources.


As the District is aware, CLWSC experienced a reduction to its pumping capacity that became acute on or about September 4, 2021. Upon further investigation, it was found that the water table had dropped to the point where well production was reduced to about 40 GPM's. We are informed that the water table has dropped by +/- 100 ft. over the past year.

CLWSC responded by installing a larger pump, motor and adding six sections or 132 ft. of column pipe. The well has now been retrofitted and is back in production. The costs of this emergency corrective work has not yet been liquidated.

As costs are identified, CLWSC respectfully requests that a portion of the 2021 grant funds be used to cover the total costs of this work. Therefore, we request an amendment to the Scope of Work from the original grant request as submitted in order to fund this corrective work. Had this emergency work not occurred, this would have resulted in an ongoing health and safety issue to CLWSC.

We appreciate your consideration of this request. If you have any questions, please do not hesitate to contact me by calling (512) 845-3230 or email pck@pgms.net.

Sincerely,



Patrick C. King, General Manager
Cade Lakes Water Supply Corporation

Cc: Mr. Larry Nichols, President
Cade Lakes Water Supply Corporation