

Blow Off Valve Update. November 8, 2022

I wanted to give you a short update on the corrosion issue that led to the June 2022 Blow Off Valve incident. A contractor has finished assessment of the line and there are approximately 15% of the vertical appurtances at high risk and in need of repair. The line must be depressurized for these repairs and they will be done in an order of feasibility and risk. Repairs will begin in December 2022 and are expected to last into 2023. Safety is the highest priority in this repair process and numerous detailed site investigations are still on-going. EPCOR will coordinate with POSGCD on any releases of water needed to conduct these repairs.

Please call me with any questions and I look forward to working with you and the board in communicating on this issue. Thanks and make it a great day,

Stefan



Stefan Schuster, P.G.

Director of Operations

EPCOR USA

11010 Coachlight Street, Suite 202

San Antonio, TX 78216

O 512-718-9298

C 512-783-6151

sschuster@epcor.com

epcor.com

This message and any attachments are solely for the use of the intended recipients. They may contain privileged and/or confidential information, attorney work product or other information protected from disclosure. If you are not an intended recipient, you received this email in error, and any review, dissemination, distribution or copying of this email or any attachments is strictly prohibited. If you received this email in error, please delete the message and any attachment from your system and contact the sender. Thank you for your cooperation.

This email message, including any attachments, is for the intended recipient(s) only, and contains confidential and proprietary information. Unauthorized distribution, copying or disclosure is strictly prohibited. If you have received this message in error, or are obviously not one of the intended recipients, please immediately notify the sender by reply email and delete this email message, including any attachments. Thank you.