



# City of Somerville

---

January 30, 2022

Mr. Gary Westbrook  
General Manager  
Post Oak Savannah Groundwater  
Conservation District  
P.O. Box 92  
Milano, Texas 76556

Re: City of Somerville, Texas  
2022 POSGCD Groundwater Conservation Grant  
Switchback Water Line Tie End

Dear Mr. Westbrook,

During our original scope of work, we assumed that there was a six-inch water line at corner of Avenue A and Switchback Rd. Upon excavating the site, we found that there was only a 2-inch water line.

The City of Somerville would like to request a change in the scope of work that will allow for an additional 660 linear feet of six-inch water line. This will ensure adequate water pressure for the area. The project will still be under budget after the change in the scope of work. We have attached a map (Exhibit A) of the area that needed the additional 6-inch water line for your review.

If you have any questions regarding the enclosed information, please feel free to contact me at 979-596-1122. Thank you.

Sincerely,

Danny Segundo  
City Administrator  
City of Somerville