

EXHIBIT A

FEBRUARY 2025

POST OAK SAVANNAH GROUNDWATER CONSERVATION DISTRICT INFORMATION FOR DISTRICT'S DASHBOARD DEMONSTRATING WATER USE, QUARTERLY INSPECTIONS, PERMITTED WATER AMOUNTS RECEIVED AND TRANSPORTED FROM DISTRICT, CONSERVATION, SPILL PREVENTION AND MITIGATION MEASURES UNDERTAKEN AND REPORTS FILED WITH TWDB AND/OR TCEQ

Shall be reviewed on an annual basis to ensure that these Actions meet the District's purposes.

Vista Ridge:

1. A checklist of items to comply with applicable District Rules, along with proof of verification of each, has been developed and shall be submitted monthly to District.
2. Well driller records, field data, and any mitigation efforts from well drillers that have not already been submitted to POSGCD will be provided. Going forward, such information will be provided within thirty (30) days after well completion.
3. The District shall be provided TWDB Annual Water Use Survey, quarterly inspection reports and/or any additional reports filed with state agencies by SAWS or EPCOR. The 2024 Water Use Survey will be completed by April 2025 and submitted to POSGCD.
4. Timely and transparent communication, including relay of information received from the ultimate user or EPCOR of any and all operations, discharges and/or sales of water in the future that involve any groundwater that is under permit from the District. There were no discharges in February 2025.

EPCOR:

1. Detailed reports of amounts of water received from VR and total amounts delivered to existing designated receivers shall be received by the District monthly.

Amount of VR water delivered by EPCOR.

Month	Delivered Water Units (AF)
January - 25	4,247.0
February – 25	3,836.0
TOTAL	8063.0

2. The District shall be provided a copy of the Vista Ridge project's Emergency Response Plan that covers spill prevention and mitigation protocols. Plan was submitted in March 2021.
3. The District shall be provided documentation establishing that the Vista Ridge project and/or EPCOR have registered the Vista Ridge project with 811. System has been registered with Texas811 since May 2020.

4. The District shall be provided a detailed report concerning the beneficial use of the amounts of water transmitted, received, discharged under the parameters of TCEQ's Hydrostatic Test General Permit No. TXG670000 or its individual equivalent, are unaccounted for or which such amounts are not delivered to the designated receivers. No events to report.

5. The District shall be provided TWDB Annual Water Use Survey, quarterly inspection reports and/or any additional reports filed with state agencies by SAWS or EPCOR. The 2023 TWDB Water Use Survey was submitted to POSGCD in March 2024. All other inspection reports will be submitted as conducted.

RULE 4.3. MONITORING REQUIREMENTS CHEKCLIST

- _____ Monitoring equipment as reasonably required installed All wells are now equipped with Badger M-2000 flow meters and data continue to be reported to POSGCD.
- _____ Wells capable for use as monitoring well (Any GCD equipment will need to meet project design specifications to comply with equipment warranties and protocols)
- _____ Well equipment has capability to measure water level and cumulative discharge rates. Meters and transducers installed in wells measure water level and flow rates and report data to centralized SCADA system continuously. Data is reported to historian on an hourly basis.
- _____ Monitoring equipment consists of transducer, a sonic water level, or equivalent technology capable of measuring within an accuracy of 0.1 ft and recording data at hourly intervals. In-Situ transducers are now installed in all wells to measure water level within 0.1 ft while recording data at hourly intervals at both Carrizo and Simsboro wells.
- _____ Monitoring equipment consists of inline totalizing meter satisfying Rules 11.2.2, 11.2.3, 11.2.4 ft and recording data at hourly intervals. Badger M-2000 mag meter installed on all wells. Data is recorded in SCADA and downloaded via historian into spreadsheet format. Network security does not allow external communication connection to SCADA system and download is via USB authorized download.
- _____ Equipment and wells are available for GCD inspection upon 7 day notice. Only one tour conducted in 2021. There were no tours in 2024. There were no tours in February 2025.
- _____ Monitoring data will be reported to the GCD electronically on a monthly basis using approved format. The submission will be emailed to the GCD with a hyperlink to the data. Well monitoring data has been submitted to RW Harden for QA/QC and electronic submission to POSGCD.
- _____ Statement that data has been checked using QA/QC protocols. Statement documenting QA/QC protocols will be signed by P.E. or P.G. and submitted to GCD on monthly basis.
- _____ Submission of data will be completed in a timely manner and by the 15th day of the following month. Historical and current month (February 2025) have been submitted to POSGCD.

Monitoring data is collected in at least 4-hour interval for each well. SCADA historian is programmed to record monitoring data on an hourly interval.

Wells allow access to collect water samples at well location. Water sampling locations are located at each well site.